

UKCA Certificate of Constancy of Performance

This is to certify that:

CVS Havalandırma Sistemleri
San. ve Tic. A.Ş.
Orta Mah. Erk Sk. A blok
No:5/A İç Kapı no:2 Tuzla İstanbul
İSTANBUL
34956
Turkey

Holds Certificate Number:

0086 CPR 783025

In respect of:

BS EN 12101-3:2015 Specification for powered smoke and heat control ventilators

In compliance with the Regulation (UK) Statutory Instrument 2019 No 465 of the United Kingdom Parliament (Construction Products (Amendment etc.) (EU Exit) Regulations or CPR), this certificate applies to the above construction product. This certificate attests that all the provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above standard(s) under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product. This certificate was first issued on the date below and will remain valid as long as neither the designated standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.

For and on behalf of BSI, an Approved Body for the above Regulation (Approved Body Number 0086):

Shahm Barhom, Group Product Certification Director

First Issued: 2024-01-24

Effective Date: 2024-01-24

Latest Issue: 2024-01-24

Page: 1 of 11



UKCA Certificate of Constancy of Performance

No. 0086 CPR 783025

EN 12101-3:2015 Product information:

CVS-AJ-Ø AXIAL JET FAN	4/8 , 4/6 , 2/4 pole		
	CVS-AJ-Ø 315	CVS-AJ-Ø 630	CVS-AJ-Ø 1400
	CVS-AJ-Ø 355	CVS-AJ-Ø 710	CVS-AJ-Ø 1600
	CVS-AJ-Ø 400	CVS-AJ-Ø 800	
	CVS-AJ-Ø 450	CVS-AJ-Ø 900	
	CVS-AJ-Ø 500	CVS-AJ-Ø 1000	
	CVS-AJ-Ø 560	CVS-AJ-Ø 1250	
Resistance to fire Class	F300		
Motor Rating	Class H; single speed , Double speed ,80-225 Frame		
Ancillaries	Terminal box Mounting Feet		
Summary Report No.:EE-21-192 Test Reports: RFTR21226, RFTR21252 , RFTR21251			

First Issued: 2024-01-24

Effective Date: 2024-01-24

Latest Issue: 2024-01-24

Page: 2 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

UKCA Certificate of Constancy of Performance

No. 0086 CPR 783025

EN 12101-3:2015 Product information:

CVS-Ø AXIAL ROOF FAN	4 pole		
	CVS-RF-Ø 315	CVS-RF-Ø 630	CVS-RF-Ø 1400
	CVS-RF-Ø 355	CVS-RF-Ø 710	CVS-RF-Ø 1600
	CVS-RF-Ø 400	CVS-RF-Ø 800	
	CVS-RF-Ø 450	CVS-RF-Ø 900	
	CVS-RF-Ø 500	CVS-RF-Ø 1000	
	CVS-RF-Ø 560	CVS-RF-Ø 1250	
Resistance to fire Class	F300		
Motor Rating	Class H; single speed 80-225 Frame		
Ancillaries	Terminal box Mounting Feet		
Summary Report No.:EE-21-192 Test Reports: RFTR21226, RFTR21252 , RFTR21251			

First Issued: 2024-01-24

Effective Date: 2024-01-24

Latest Issue: 2024-01-24

Page: 3 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

UKCA Certificate of Constancy of Performance

No. 0086 CPR 783025

EN 12101-3:2015 Product information:

CVS-Ø AXIAL ROOF FAN	2 pole		
	CVS-RF-Ø 315	CVS-RF-Ø 630	
	CVS-RF-Ø 355	CVS-RF-Ø 710	
	CVS-RF-Ø 400	CVS-RF-Ø 800	
	CVS-RF-Ø 450		
	CVS-RF-Ø 500		
	CVS-RF-Ø 560		
Resistance to fire Class	F300		
Motor Rating	Class H; single speed 80-225 Frame		
Ancillaries	Terminal box Mounting Feet		
Summary Report No.:EE-21-192 Test Reports: RFTR21226, RFTR21252 , RFTR21251			

First Issued: 2024-01-24

Effective Date: 2024-01-24

Latest Issue: 2024-01-24

Page: 4 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

UKCA Certificate of Constancy of Performance

No. 0086 CPR 783025

EN 12101-3:2015 Product information:

CVS-Ø AXIAL CABINET FAN	4 pole		
	CVS-H-Ø 315	CVS-H-Ø 630	CVS-H-Ø 1400
	CVS-H-Ø 355	CVS-H-Ø 710	CVS-H-Ø 1600
	CVS-H-Ø 400	CVS-H-Ø 800	
	CVS-H-Ø 450	CVS-H-Ø 900	
	CVS-H-Ø 500	CVS-H-Ø 1000	
	CVS-H-Ø 560	CVS-H-Ø 1250	
Resistance to fire Class	F300		
Motor Rating	Class H; single speed 80-225 Frame		
Ancillaries	Terminal box Mounting Feet		
Summary Report No.:EE-21-192 Test Reports: RFTR21226, RFTR21252 , RFTR21251			

First Issued: 2024-01-24

Effective Date: 2024-01-24

Latest Issue: 2024-01-24

Page: 5 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

UKCA Certificate of Constancy of Performance

No. 0086 CPR 783025

EN 12101-3:2015 Product information:

CVS-Ø AXIAL CABINET FAN	2 pole		
	CVS-H-Ø 315	CVS-H-Ø 630	
	CVS-H-Ø 355	CVS-H-Ø 710	
	CVS-H-Ø 400	CVS-H-Ø 800	
	CVS-H-Ø 450		
	CVS-H-Ø 500		
	CVS-H-Ø 560		
Resistance to fire Class	F300		
Motor Rating	Class H; single speed 80-225 Frame		
Ancillaries	Terminal box Mounting Feet		
Summary Report No.:EE-21-192 Test Reports: RFTR21226, RFTR21252 , RFTR21251			

First Issued: 2024-01-24

Effective Date: 2024-01-24

Latest Issue: 2024-01-24

Page: 6 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

UKCA Certificate of Constancy of Performance

No. 0086 CPR 783025

EN 12101-3:2015 Product information:

CVS-Ø AXIAL DUCT FAN SINGLE SPEED	2 pole		
	CVS-Ø 315	CVS-Ø 630	
	CVS-Ø 355	CVS-Ø 710	
	CVS-Ø 400	CVS-Ø 800	
	CVS-Ø 450		
	CVS-Ø 500		
	CVS-Ø 560		
Resistance to fire Class	F300		
Motor Rating	Class H; single speed 80-225 Frame		
Ancillaries	Terminal box Mounting Feet		
Summary Report No.:EE-21-192 Test Reports: RFTR21226, RFTR21252 , RFTR21251			

First Issued: 2024-01-24

Effective Date: 2024-01-24

Latest Issue: 2024-01-24

Page: 7 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

UKCA Certificate of Constancy of Performance

No. 0086 CPR 783025

EN 12101-3:2015 Product information:

CVS-Ø AXIAL DUCT FAN SINGLE SPEED	4 pole		
	CVS-Ø 315	CVS-Ø 630	CVS-Ø 1400
	CVS-Ø 355	CVS-Ø 710	CVS-Ø 1600
	CVS-Ø 400	CVS-Ø 800	
	CVS-Ø 450	CVS-Ø 900	
	CVS-Ø 500	CVS-Ø 1000	
	CVS-Ø 560	CVS-Ø 1250	
Resistance to fire Class	F300		
Motor Rating	Class H; single speed 80-225 Frame		
Ancillaries	Terminal box Mounting Feet		
Summary Report No.:EE-21-192 Test Reports: RFTR21226, RFTR21252 , RFTR21251			

First Issued: 2024-01-24

Effective Date: 2024-01-24

Latest Issue: 2024-01-24

Page: 8 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

UKCA Certificate of Constancy of Performance

No. 0086 CPR 783025

EN 12101-3:2015 Product information:

CVS-Ø AXIAL DUCT FAN DOUBLE SPEED	4/8 , 4/6 , 2/4 pole		
	CVS-DS-Ø 315	CVS-DS-Ø 630	CVS-DS-Ø 1400
	CVS-DS-Ø 355	CVS-DS-Ø 710	CVS-DS-Ø 1600
	CVS-DS-Ø 400	CVS-DS-Ø 800	
	CVS-DS-Ø 450	CVS-DS-Ø 900	
	CVS-DS-Ø 500	CVS-DS-Ø 1000	
	CVS-DS-Ø 560	CVS-DS-Ø 1250	
Resistance to fire Class	F300		
Motor Rating	Class H; single speed 80-225 Frame		
Ancillaries	Terminal box Mounting Feet		
Summary Report No.:EE-21-192 Test Reports: RFTR21226, RFTR21252 , RFTR21251			

First Issued: 2024-01-24

Effective Date: 2024-01-24

Latest Issue: 2024-01-24

Page: 9 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

UKCA Certificate of Constancy of Performance

No. 0086 CPR 783025

EN 12101-3:2015 Product information:

CVS-RADIAL JET FAN	4, 4/8 , 4/6		
	CVS-RJ 60N/R		
	CVS-RJ 100N/R		
Resistance to fire Class	F300		
Motor Rating	Class H; single speed ,double speed		
Ancillaries	Terminal box		
Summary Report No. : EEA - 15 – 035-rev Test Reports: RFTR15036-rev , RFTR15037-rev			

First Issued: 2024-01-24

Effective Date: 2024-01-24

Latest Issue: 2024-01-24

UKCA Certificate of Constancy of Performance

No. 0086 CPR 783025

EN 12101-3:2015 Product information:

CVS-Ø AXIAL FAN F400	4/8 , 4/6 , 2/4 pole , 2, 4 pole		
	CVS-Ø 315	CVS-Ø 630	
	CVS-Ø 355	CVS-Ø 710	
	CVS-Ø 400	CVS-Ø 800	
	CVS-Ø 450	CVS-Ø 900	
	CVS-Ø 500	CVS-Ø 1000	
	CVS-Ø 560	CVS-Ø 1250	
Resistance to fire Class	F400		
Motor Rating	Class H; single speed ,double speed, 90-200 Frame		
Ancillaries	Terminal box Mounting Feet		
Summary Report No. : EEA - 17 – 067-rev Test Reports: RFTR17032-rev , RFTR17091-rev , RFTR170-2 rev			

Manufacturing plant

CVS Havalandırma Sistemleri
San. ve Tic. A.Ş.
Orta Mah. Erk Sk. A blok
No:5/A İç Kapı no:2 Tuzla Istanbul
ISTANBUL
34956
Turkey

Certified Activities

EN 12101-3:2015
Powered smoke and heat exhaust ventilators

First Issued: 2024-01-24

Effective Date: 2024-01-24

Latest Issue: 2024-01-24

Page: 11 of 11

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.